



Ph: 26856360/61
26856071/585
Fax: 26856596

MAHANAND DAIRY

MRSDDMM MAHARASHTRA RAJYA SAHAKARI DUDH MAHASANGH MARYADIT
Unit No. 12, Aarey colony, Western Express Highway, Goregaon (E), Mumbai-400065

ENQUIRY

Ref.No.MND/6/ENGG/2022-23 /0723

Date: - 30 /05/2022

Under Postal Certificate

TO,

M/S. _____

Dear Sir,

Kindly submit your lowest offer for the following items mentioned below. Quotations may please be sent to us on or **before 10/06/2022**. Quotation received after the due date mentioned herein will not be considered. Quotation should be send in sealed cover duly marked as Quotation for :- **Comprehensive Annual Maintenance of @ -20° C Butter Deep Freezer.**

Sr. No	Description	Quantity Required
1	<p>Comprehensive Annual Maintenance of minius - 20°C Butter Deep Freezer (Cap. 12. M.T.) as per Attached Annexure - A at Mahanand Dairy Goregaon (East), Mumbai – 400 065.</p> <p>Terms and Conditions :-</p> <p>1) The rate should be quoted with labour, Equipments, taxes and Duties etc.</p>	1 JOB

T. Patel
30.05.22
A/C Manager (Engg.)



ANNEXURE " A "

SCOPE FOR AMC OF BUTTER DEEP FREEZER

- 1) Monthly visit for visual inspection of Butter deep freezer refrigeration system to maintain continuous - 20⁰ C deep freezer temperature and - 18⁰ C Storage Products temperature.
- 2) To check and service all the equipments connected in the deep freezer refrigeration units every alternate month.
- 3) To attend break-down calls within 24 hrs. in Comprehensive AMC period.
- 4) Checking of refrigeration system including indoor and outdoor units for proper functioning at all times .
- 5) Replacement / repairing of the defective or worn out parts at site / service station for maintaining proper working of the system to maintain specified temperature.
- 6) Replacements of the refrigerant gas, compressor oil, in the system for proper working of the system as and when required.
- 7) Replacement of parts due to normal wear and tear during normal operation of the system.
- 8) Compressor, condenser coils, thermostat, evaporator and defrosting system to be checked for proper working of the system.
- 9) Comprehensive Preventive Maintenance and servicing once in every three months.
- 10) Supplying electrical & mechanical spare parts which are part of the machine.
- 11) Checking the refrigerant piping for signs of leaks and repairing the leaks, if any.
- 12) Checking the machine, compressor and other drives for undue vibrations.
- 13) Cleaning the air filters, evaporator coil, and finned surface of the condenser with air blower.
- 14) Ensuring the condensate drain is not clogged.
- 15) Greasing of motor and blower bearings if required.
- 16) Checking tightness of all electrical connections and fuse links.

A/C MANAGER(ENGG.)